



1010 EAST 31st STREET
HIALEAH, FLORIDA 33013

PHONE (305) 687-4121

FAX (305) 687-3743

EC Declaration of Conformity

Machinery Directive 2006/42/EC Annex IIA

We,

CPS Products, Inc.
1010 East 31st Street
Hialeah, Florida 33013
USA

hereby declare that the machine:

TRS21E, Refrigerant Recovery Unit

Complies with the following directives:

**Machinery Directive 2006/42/EC
Low voltage Directive 2006/95/EC
Pressure Equipment Directive 97/23/EC**

Other applied directives

EMC Directive 2014/30/EU

Applied harmonized standards:

**EN 378-1:2008 Refrigerating systems and heat pumps
EN 378-2:2009 Refrigerating systems and heat pumps
EN ISO 12100-1&2:2005 Machinery safety
SAE J2843 Issued 2013/01/14
EN ISO 13857 Safety distances
EN 60204-1:2006 Electrical equipment of machinery
EN 61000-6-1&-2:2006 Interference emissions & immunity
ANSI/ISA-12.12.01-2007 Nonincendive Electr equipm Class I / II and III**

Applied national technical specifications, in particular:

This declaration of EC conformity shall become null and void when the assembly is subjected to any modification that has not met with our approval.

Hialeah, Florida 33013 USA

Signature and Date

July 28, 2017

Richard Koldewey, VP Engineering CPS Products

Typed Name and Title



1717 Arlingate Lane
Columbus, OH 43228

Telephone: 614-279-8090
Facsimile: 614-279-4642
www.intertek.com

Findings Report

October 29, 2014

Intertek Report No. 101844511COL-001
Intertek Project No. G101844511

Rich Koldewey
CPS PRODUCTS, INC.
1010 East 31st Street
Hialeah, FL 33013
rkoldewey@cpsproducts.com

Ph: 305-687-4121 Ext. 127
Fx: 305-687-3743

Subject: Spark Proof Protection testing on the following components:
1. Spark Proof Vacuum Pump (VPS series)
2. Spark Proof Compressor (TRS series)

Dear Mr. Koldewey,

This letter report represents the results of our evaluation of the above referenced product(s) to the requirements contained in the following standards:

*SAE J2843 Issued: 2013/01/14 R-1234YF [HFO-1234YF]
RECOVERY/RECYCLING/RECHARGING EQUIPMENT FOR FLAMMABLE
REFRIGERANTS FOR MOBILE AIR-CONDITIONING SYSTEMS
&
ANSI/ISA-12.12.01-2007 Nonincendive Electrical Equipment for Use in Class I and II,
Division 2 and Class III, Divisions 1 and 2 Hazardous (Classified) Locations*

SECTION 1: SUMMARY

Intertek is pleased to inform you that both the VPS6DE/A Vacuum Pump and the TRS21 Compressor have passed the ignition test requirements of ANSI/ISA-12.12.01, section 12, evaluation of nonincendive components. At no time during testing did either sample cause ignition of stoichiometrically explosive propane-air mixtures.

SECTION 2: TESTING

The list below represents a summary of the tests & results, including any which are pending completion or have yet to be conducted.

Completed Tests:

Test Location: Intertek, Columbus, OH

Test Description	Standard	Section	Results
Evaluation of Nonincendive Components	ANSI/ISA-12.12.01	12	Pass

Pending Tests:

Test Description	Standard	Section
None		

For a complete description of testing, please see accompanying Test Data Package (TDP).

This information is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense, or damage occasioned by the use of this information. Any observations and results in this report are relevant only to the sample evaluated. Only the Client is authorized to copy and distribute this information and only then in its entirety.

Findings Report

SECTION 3: PHOTOGRAPHS

Please see accompanying Test Data Package (TDP).

SECTION 4: PROJECT STATUS & CONCLUSION

Issuance of this letter report completes the testing portion covered by Intertek Project No. G101844511.

The VPS6DE/A Vacuum Pump and the TRS21 Compressor have been evaluated and found to not cause ignition to flammable propane-air mixtures and therefore are suitable for use in R-1234yf service equipment as required in SAE J2843. The vacuum pump and compressor are also suitable for use with other flammable refrigerants, including hydrocarbons, provided that said refrigerants are within the design pressure specifications and material compatibility of the respective vacuum pump and compressor.

If there are any questions regarding the results contained in this report, or any of the other services offered by Intertek, please do not hesitate to contact your dedicated Intertek Project Manager.


Completed by: Brandon Button
Senior Associate
Engineer

Reviewed by: Jody Coffman
Associate Engineer

Signature:



Signature



Date

October 29, 2014

Date:

October 29, 2014

Please note: this Letter Report does not represent authorization for the use of any Intertek certification marks.